



# Douglas Public Schools

21 Davis Street, Douglas, MA 01516 (508) 476-7901 FAX (508) 476-3719 [www.douglasps.net](http://www.douglasps.net)

---

Norman Yvon, Superintendent

Cortney Keegan, Business Manager  
Cindy Socha, Curriculum Director

Donna Sousa, Director of Technology  
Nealy Urquhart, Director of Student Support Services

October 21, 2016

Dear Douglas Elementary School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our school community, the Douglas Public Schools tested our drinking water for lead in each of our schools. We have received the results for Douglas Elementary School.

Of the 58 samples taken at the elementary school **all** tested safe for both lead and copper.

You can see a copy of the school's water testing results in the District central office, at the Middle School, which is open from 8:00 AM – 3:30 PM and on our District web-site, [www.douglasps.net](http://www.douglasps.net).

For information about water quality and sampling for lead at home, contact the Massachusetts Department of Environmental Protection (DEP) or enter the following link into your web browser: <http://www.mass.gov/eea/agencies/massdep/water/drinking/is-there-lead-in-my-tap-water.html>.

Sincerely,

Norman P. Yvon  
Superintendent of Schools

Sam Cederbaum  
Principal Douglas Elementary School

*Excellence in Education*

It is the policy of the Douglas Public Schools not to discriminate on the basis of race, color, gender, religion, national origin, sexual orientation, gender identity, disability, age, or homelessness in its educational programs, services, activities, or employment.

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result

SCHOOL NAME	SCHOOL TYPE	CATION	SAMPLE LOCATION NAME	ANALYTENAME	RESULT	MEASUREMENT
Douglas: Douglas Elementary School	Public School	001F	115 UPPER	COPPER	0.0012	MG/L
Douglas: Douglas Elementary School	Public School	001F	115 UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	001P	115 UPPER	COPPER	0.011	MG/L
Douglas: Douglas Elementary School	Public School	001P	115 UPPER	LEAD	0.0034	MG/L
Douglas: Douglas Elementary School	Public School	002P	115 LOWER	COPPER	0.012	MG/L
Douglas: Douglas Elementary School	Public School	002P	115 LOWER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	003F	107/108 UPPER	COPPER	0.45	MG/L
Douglas: Douglas Elementary School	Public School	003F	107/108 UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	003P	107/108 UPPER	COPPER	0.58	MG/L
Douglas: Douglas Elementary School	Public School	003P	107/108 UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	004P	107/108 LOWER	COPPER	0.45	MG/L
Douglas: Douglas Elementary School	Public School	004P	107/108 LOWER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	005F	243/244 UPPER	COPPER	0.31	MG/L
Douglas: Douglas Elementary School	Public School	005F	243/244 UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	005P	243/244 UPPER	COPPER	0.19	MG/L

MEASUREMENT

Douglas: Douglas Elementary School	Public School	005P	243/244 UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	006P	243/244 LOWER	COPPER	0.30	MG/L
Douglas: Douglas Elementary School	Public School	006P	243/244 LOWER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	007F	209/ELEVATOR UPPER	COPPER	0.031	MG/L
Douglas: Douglas Elementary School	Public School	007F	209/ELEVATOR UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	007P	209/ELEVATOR UPPER	COPPER	0.035	MG/L
Douglas: Douglas Elementary School	Public School	007P	209/ELEVATOR UPPER	LEAD	0.0017	MG/L
Douglas: Douglas Elementary School	Public School	008P	209/ELEVATOR LOWER	COPPER	0.037	MG/L
Douglas: Douglas Elementary School	Public School	008P	209/ELEVATOR LOWER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	009F	219/220 UPPER	COPPER	0.43	MG/L
Douglas: Douglas Elementary School	Public School	009F	219/220 UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	009P	219/220 UPPER	COPPER	0.55	MG/L
Douglas: Douglas Elementary School	Public School	009P	219/220 UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	010P	219/220 LOWER	COPPER	0.42	MG/L
Douglas: Douglas Elementary School	Public School	010P	219/220 LOWER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	011F	309/ELEVATOR UPPER	COPPER	0.0017	MG/L
Douglas: Douglas Elementary School	Public School	011F	309/ELEVATOR UPPER	LEAD	ND	MG/L

Douglas: Douglas Elementary School	Public School	011P	309/ELEVATOR UPPER	COPPER	0.010	MG/L
Douglas: Douglas Elementary School	Public School	011P	309/ELEVATOR UPPER	LEAD	0.0018	MG/L
Douglas: Douglas Elementary School	Public School	012P	309/ELEVATOR LOWER	COPPER	0.017	MG/L
Douglas: Douglas Elementary School	Public School	012P	309/ELEVATOR LOWER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	013F	319/320 UPPER	COPPER	0.35	MG/L
Douglas: Douglas Elementary School	Public School	013F	319/320 UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	013P	319/320 UPPER	COPPER	0.37	MG/L
Douglas: Douglas Elementary School	Public School	013P	319/320 UPPER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	014P	319/320 LOWER	COPPER	0.33	MG/L
Douglas: Douglas Elementary School	Public School	014P	319/320 LOWER	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	015F	KITCHEN FOOD PREP SINK #1	COPPER	0.079	MG/L
Douglas: Douglas Elementary School	Public School	015F	KITCHEN FOOD PREP SINK #1	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	015P	KITCHEN FOOD PREP SINK #1	COPPER	0.16	MG/L
Douglas: Douglas Elementary School	Public School	015P	KITCHEN FOOD PREP SINK #1	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	016F	KITCHEN FOOD PREP SINK #2	COPPER	0.080	MG/L
Douglas: Douglas Elementary School	Public School	016F	KITCHEN FOOD PREP SINK #2	LEAD	ND	MG/L
Douglas: Douglas Elementary School	Public School	016P	KITCHEN FOOD PREP SINK #2	COPPER	0.26	MG/L

